

Certificate of test

Particle size distribution (by washing and sieving)



Tested in accordance with BS EN 933-1: 2012


Prepared in accordance with BS EN 932-2: 1999

Laboratory Reference: OCMT-6850-2714	Certificate Reference: OCMT-6850-2714-A03-WS
Client: Towens of Weston Ltd	Issue Number: 1.1
Clients Address: Plot 2, Warne Road, , Weston Super Mare, BS23 3UU	Client Order Number: Towens Monthly
Site: Westonzoyland	

Sample Reference: 0/4mm Grit Sand	Sample Certificate: Yes - See enclosed
Source: Ex-site	Date Sampled: 29/11/2023
Location of Sample on Site: Stockpile	Sampled by: D.Paris (OEMA)
Material Description: 0/4mm Reclaimed Grit Sand	Date Received: 29/11/2023
Clients Indicated Specification: BS EN 12620: 0/4mm MP Recycled	Date Tested: 13/12/2023

Result:

ISO 565 Sieve Aperture (mm)	Percentage Passing (%)	Specification (Passing)	
		Lower (%)	Upper (%)
125.00	100		
80.00	100		
63.00	100		
40.00	100		
31.50	100		
20.00	100		
16.00	100		
14.00	100		
10.00	100		
8.00	100	100	100
6.30	100	95	100
4.00	99	85	99
2.80	94		
2.00	86		
1.00	71		
0.500	58	30	70
0.250	35		
0.125	6		
0.063	2.0	0	3



Fractions where required (differences in values passing selected sieves)			
Uniformity Co-efficient			
D100 (mm)	6.3		
D60 (mm)	0.577		
D10 (mm)	0.142		
U/C (nr.)	4.06		

Remarks: This sample complies with the clients indicated grading specification

Approved By: 
 Date Approved: **14/12/2023**
 Sheet Ref: **A03-WS-Rev6-Nov23**

Refer to the remarks section for any additions, deviations or exclusions from the stated test & preparation methods. The results within this test report are representative of the samples submitted at the time of analysis. This test report should not be reproduced, except in full, without the express permission of the Issuing laboratory. Bulk samples are retained for a period of 28 days from receipt. Any opinions or interpretations indicated are outside the scope of our accreditation. Simplified decision rules apply to any statements of compliance made on the test report. Where a sample has not been taken by Oema Chem Ltd, the test results apply to the sample as received.

Oema Chem Limited
T/A OEMA
 Unit 1 - Building 267A
 Commercial Road
 Christchurch
 Dorset
 BH23 6NW

